



MAJOR SOURCE OPERATING PERMIT

Permitee: **CER Generation, LLC**

Facility Name: Hillabee Power Plant

Facility No.: 310-0022

Location: Alexander City, Tallapoosa County, Alabama

In accordance with and subject to the provisions of the Alabama Air Pollution Control Act of 1971, as amended, <u>Ala. Code</u> 1975, §§22-28-1 to 22-28-23 (2006 Rplc. Vol. and 2007 Cum. Supp.) (the "AAPCA") and the Alabama Environmental Management Act, as amended, <u>Ala. Code</u> 1975, §§22-22A-1 to 22-22A-15, (2006 Rplc. Vol. and 2007 Cum. Supp.) and rules and regulations adopted thereunder, and subject further to the conditions set forth in this permit, the Permittee is hereby authorized to construct, install and use the equipment, device or other article described above.

Pursuant to the Clean Air Act of 1990, all conditions of this permit are federally enforceable by EPA, the Alabama Department of Environmental Management, and citizens in general. Those provisions which are not required under the Clean Air Act of 1990 are considered to be state permit provisions and are not federally enforceable by EPA and citizens in general. Those provisions are contained in separate sections of this permit.

Issuance Date: Draft

Expiration Date: Draft

TABLE OF CONTENTS

ACID RAIN PERMITATT	ACHED3
GENERAL PERMIT PROVISOS	4
SUMMARY PAGE FOR TWO (2) COMBINED CYCLE COMBUSTION TURBINE TWO (2) HEAT RECOVERY STEAM GENERATORS WITH DUCT BURNERS A SELECTIVE CATALYTIC REDUCTION (SCR)	ND
PERMITTED OPERATING SCHEDULE: 8760 HRS/YR	16
PROVISOS FOR TWO (2) COMBINED CYCLE COMBUSTION TURBINES AND (2) HEAT RECOVERY STEAM GENERATORS WITH DUCT BURNERS AND SELECTIVE CATALYTIC REDUCTION (SCR)	
Applicability	17
Emission Standards	17
Compliance and Performance Test Methods and Procedures	20
Emission Monitoring	20
Recordkeeping and Reporting Requirements	21
SUMMARY PAGE FOR 11.64 MMBTU/HR INDIRECT-FIRED FUEL HEATER	24
PERMITTED OPERATING SCHEDULE: 8760 HRS/YR	24
Applicability	25
Emission Standards	25
Compliance and Performance Test Methods and Procedures	25
Emission Monitoring	26
Recordkeeping and Reporting Requirements	26
SUMMARY PAGE FOR MACT SUBPART ZZZZ – EXISTING EMERGENCY FIREWATER PUMP	27
PROVISOS FOR MACT SUBPART ZZZZ - EXISTING EMERGENCY RICE ENG	GINES28
Applicability	28
Emission Standards	28
Compliance and Performance Test Methods and Procedures	29

1	ACID RAIN PERMIT	TACHED
	Recordkeeping and Reporting Requirements	30
	Emission Monitoring	29

Fed	erally E	Enforceable Provisos	Regulations
1.	Tran	sfer	
	or ot piece	permit is not transferable, whether by operation of law herwise, either from one location to another, from one of equipment to another, or from one person to her, except as provided in Rule 335-3-1613(1)(a)5.	Rule 335-3-1602(6)
2.	Rene	ewals	
	six (pplication for permit renewal shall be submitted at least 6) months, but not more than eighteen (18) months, re the date of expiration of this permit.	Rule 335-3-1612(2)
	to op and	source for which this permit is issued shall lose its right perate upon the expiration of this permit unless a timely complete renewal application has been submitted in the time constraints listed in the previous paragraph.	
3.	Seve	rability Clause	
	and claus inval juris inval confi subp that	provisions of this permit are declared to be severable if any section, paragraph, subparagraph, subdivision, se, or phrase of this permit shall be adjudged to be id or unconstitutional by any court of competent diction, the judgment shall not affect, impair, or idate the remainder of this permit, but shall be ned in its operation to the section, paragraph, paragraph, subdivision, clause, or phrase of this permit shall be directly involved in the controversy in which judgment shall have been rendered.	Rule 335-3-1605(e)
4.	Com	<u>pliance</u>	
	(a)	The permittee shall comply with all conditions of ADEM Admin. Code 335-3. Noncompliance with this permit will constitute a violation of the Clean Air Act of 1990 and ADEM Admin. Code 335-3 and may result in an enforcement action; including but not limited to, permit termination, revocation and reissuance, or modification; or denial of a permit renewal application by the permittee.	Rule 335-3-1605(f)
	(b)	The permittee shall not use as a defense in an enforcement action that maintaining compliance with conditions of this permit would have required halting	Rule 335-3-1605(g)

Fede	rally Enforceable Provisos	Regulations
	or reducing the permitted activity.	
5.	Termination for Cause	
	This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance will not stay any permit condition.	Rule 335-3-1605(h)
6.	Property Rights	
	The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege.	Rule 335-3-1605(i)
7.	Submission of Information	
	The permittee must submit to the Department, within 30 days or for such other reasonable time as the Department may set, any information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. Upon receiving a specific request, the permittee shall also furnish to the Department copies of records required to be kept by this permit.	Rule 335-3-1605(j)
8.	Economic Incentives, Marketable Permits, and Emissions Trading	
	No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.	Rule 335-3-1605(k)
9.	Certification of Truth, Accuracy, and Completeness:	
	Any application form, report, test data, monitoring data, or compliance certification submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.	Rule 335-3-1607(a)

Fede	rally l	Enforceable Provisos	Regulations
10.	Insp	ection and Entry	
	may repre Envi	n presentation of credentials and other documents as be required by law, the permittee shall allow authorized esentatives of the Alabama Department of ronmental Management and EPA to conduct the wing:	Rule 335-3-1607(b)
	(a)	Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept pursuant to the conditions of this permit;	
	(b)	Review and/or copy, at reasonable times, any records that must be kept pursuant to the conditions of this permit;	
	(c)	Inspect, at reasonable times, this facility's equipment (including monitoring equipment and air pollution control equipment), practices, or operations regulated or required pursuant to this permit;	
	(d)	Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or other applicable requirements.	
11.	Com	pliance Provisions	
	(a)	The permittee shall continue to comply with the applicable requirements with which the company has certified that it is already in compliance.	Rule 335-3-1607(c)
	(b)	The permittee shall comply in a timely manner with applicable requirements that become effective during the term of this permit.	
12.	Com	pliance Certification	
	two imme this acco	mpliance certification shall be submitted yearly within months of the end of the calendar quarter that ediately precedes the anniversary date of issuance of permit unless more frequent periods are specified rding to the specific rule governing the source or ired by the Department.	Rule 335-3-1607(e)

Fede	rally E	nforce	able Provisos	Regulations
	(a)	The follow	compliance certification shall include the ving:	
		(1)	The identification of each term or condition of this permit that is the basis of the certification;	
		(2)	The compliance status;	
		(3)	The method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with Rule 335-3-1605(c) (Monitoring and Recordkeeping Requirements);	
		(4)	Whether compliance has been continuous or intermittent;	
		(5)	Such other facts as the Department may require to determine the compliance status of the source;	
	(b)	The c	compliance certification shall be submitted to:	
	Alab	ama D	epartment of Environmental Management Air Division P.O. Box 301463 Montgomery, AL 36130-1463	
			and to:	
		Air	and EPCRA Enforcement Branch EPA Region IV 61 Forsyth Street, SW Atlanta, GA 30303	
13.	Reop	ening	for Cause	
			of the following circumstances, this permit will be rior to the expiration of the permit:	Rule 335-3-1613(5)
	(a)	Air A with years than	cional applicable requirements under the Clean act of 1990 become applicable to the permittee a remaining permit term of three (3) or more s. Such a reopening shall be completed not later eighteen (18) months after promulgation of the cable requirement. No such reopening is	

Fede	rally I	Enforce	able Provisos	Regulations
			red if the effective date of the requirement is than the date on which this permit is due to e.	
	(b)	requisource source by th	ional requirements (including excess emissions rements) become applicable to an affected se under the acid rain program. Upon approval the Administrator, excess emissions offset plans be deemed to be incorporated into this permit.	
	(c)	conta state:	Department or EPA determines that this permit ins a material mistake or that inaccurate ments were made in establishing the emissions lards or other terms or conditions of this permit.	
	(d)	this	Administrator or the Department determines that permit must be revised or revoked to assure liance with the applicable requirements.	
14.	<u>Addi</u>	itional	Rules and Regulations	
	exist Rule	ing on s and	is issued on the basis of Rules and Regulations the date of issuance. In the event additional Regulations are adopted, it shall be the permit ponsibility to comply with such rules.	§22-28-16(d), Code of Alabama 1975, as amended
15.	<u>Equi</u>	<u>ipment</u>	Maintenance or Breakdown	
	(a)	equip issue main equip twent shute the si	ne case of shutdown of air pollution control oment (which operates pursuant to any permit d by the Director) for necessary scheduled tenance, the intent to shut down such oment shall be reported to the Director at least ty-four (24) hours prior to the planned down, unless such shutdown is accompanied by hutdown of the source which such equipment is ded to control. Such prior notice shall include, a not limited to the following:	Rule 335-3-107(1), (2)
		(1)	Identification of the specific facility to be taken out of service as well as its location and permit number;	
		(2)	The expected length of time that the air pollution control equipment will be out of	

Fede	rally l	Enforce	eable Provisos	Regulations
			service;	
		(3)	The nature and quantity of emissions of air contaminants likely to occur during the shutdown period;	
		(4)	Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period;	
		(5)	The reasons that it would be impossible or impractical to shut down the source operation during the maintenance period.	
	(b)	or up is exconta stand shall work pertinate the terms of the standard shall work and the standard shall work shall	the event that there is a breakdown of equipment oset of process in such a manner as to cause, or expected to cause, increased emissions of air aminants which are above an applicable dard, the person responsible for such equipment notify the Director within 24 hours or the next ing day and provide a statement giving all nent facts, including the estimated duration of breakdown. The Director shall be notified when breakdown has been corrected.	
16.	<u>Ope</u>	ration (of Capture and Control Devices	
	whice oper emission the a	ch this ated at ssions of above e	ution control devices and capture systems for permit is issued shall be maintained and all times in a manner so as to minimize the of air contaminants. Procedures for ensuring that quipment is properly operated and maintained so mize the emission of air contaminants shall be	§22-28-16(d), Code of Alabama 1975, as amended
17.	<u>Obn</u>	oxious	Odors	
	obnoverif odor the	oxious ied by rous em Alaban these	it is issued with the condition that, should odors arising from the plant operations be Air Division inspectors, measures to abate the hissions shall be taken upon a determination by ha Department of Environmental Management measures are technically and economically	Rule 335-3-108

Fede	derally Enforceable Provisos Regulations			
18.	3. Fugitive Dust			
	(a)	eman	autions shall be taken to prevent fugitive dust nating from plant roads, grounds, stockpiles, ens, dryers, hoppers, ductwork, etc.	Rule 335-3-402
	(b)	in th airbo follov	or haul roads and grounds will be maintained e following manner so that dust will not become rne. A minimum of one, or a combination, of the ving methods shall be utilized to minimize rne dust from plant or haul roads and grounds:	
		(1)	By the application of water any time the surface of the road is sufficiently dry to allow the creation of dust emissions by the act of wind or vehicular traffic;	
		(2)	By reducing the speed of vehicular traffic to a point below that at which dust emissions are created;	
		(3)	By paving;	
		(4)	By the application of binders to the road surface at any time the road surface is found to allow the creation of dust emissions;	
	adeq and exclu contr Alter	uately ground Isively rol tech native	, or a combination, of the above methods fail to reduce airborne dust from plant or haul roads is, alternative methods shall be employed, either or in combination with one or all of the above iniques, so that dust will not become airborne. methods shall be approved by the Department ization.	
19.	<u>Addi</u>	tions a	and Revisions	
			cations to this source shall comply with the procedures in Rules 335-3-1613 or 335-3-16-	Rule 335-3-1613 and .14
20.	Reco	rdkee	ping Requirements	
	(a)		rds of required monitoring information of the ce shall include the following:	Rule 335-3-1605(c)2

Fede	rally I	Enforce	eable Provisos	Regulations
		(1)	The date, place, and time of all sampling or measurements;	
		(2)	The date analyses were performed;	
		(3)	The company or entity that performed the analyses;	
		(4)	The analytical techniques or methods used;	
		(5)	The results of all analyses; and	
		(6)	The operating conditions that existed at the time of sampling or measurement.	
	(b)	and s at le samp Supp main recor	ntion of records of all required monitoring data support information of the source for a period of east 5 years from the date of the monitoring ole, measurement, report, or application. For information includes all calibration and attenance records and all original strip-chart redings for continuous monitoring instrumentation copies of all reports required by the permit	
21.	Repo	orting 1	Requirements	
	(a)	shall insta must repor	orts to the Department of any required monitoring be submitted at least every 6 months. All ences of deviations from permit requirements to be clearly identified in said reports. All required ents must be certified by a responsible official istent with Rule 335-3-1604(9).	Rule 335-3-1605(c)3
	(b)	repor devia cond inclu any	ations from permit requirements shall be read within 48 hours or 2 working day of such ations, including those attributable to upset itions as defined in the permit. The report will de the probable cause of said deviations, and corrective actions or preventive measures that taken.	
22.	<u>Emi</u>	ssion T	Cesting Requirements	
	provi	ided wi	t of emission which requires testing will be th sampling ports, ladders, platforms, and other aipment to facilitate testing performed in	Rule 335-3-105(3) and Rule 335-3-1-

Fede	rally E	nforceable Provisos	Regulations
	accordance with procedures established by Part 60 of Title 40 of the Code of Federal Regulations, as the same may be amended or revised.		.04(1)
	in ac subm	air Division must be notified in writing at least 10 days dvance of all emission tests to be conducted and aitted as proof of compliance with the Department's air tion control rules and regulations.	
	proce	avoid problems concerning testing methods and dures, the following shall be included with the cation letter:	
	(1)	The date the test crew is expected to arrive, the date and time anticipated of the start of the first run, how many and which sources are to be tested, and the names of the persons and/or testing company that will conduct the tests.	Rule 335-3-104
	(2)	A complete description of each sampling train to be used, including type of media used in determining gas stream components, type of probe lining, type of filter media, and probe cleaning method and solvent to be used (if test procedures require probe cleaning).	
	(3)	A description of the process(es) to be tested including the feed rate, any operating parameters used to control or influence the operations, and the rated capacity.	
	(4)	A sketch or sketches showing sampling point locations and their relative positions to the nearest upstream and downstream gas flow disturbances.	
	owner and t	test meeting may be held at the request of the source r or the Air Division. The necessity for such a meeting he required attendees will be determined on a case-by- pasis.	Rule 335-3-104
	All test reports must be submitted to the Air Division within 30 days of the actual completion of the test unless an extension of time is specifically approved by the Air Division.		
23.	3. Payment of Emission Fees		
		al emission fees shall be remitted each year according fee schedule in ADEM Admin. Code R. 335-1-704.	Rule 335-1-704

Fede	rally Enforc	eable Provisos	Regulations
24.	Other Rep	orting and Testing Requirements	
	fuel analys may be re pollution o	n of other reports regarding monitoring records, ses, operating rates, and equipment malfunctions equired as authorized in the Department's air control rules and regulations. The Department re emission testing at any time.	Rule 335-3-104(1)
5.	Title VI Re	equirements (Refrigerants)	
	including a Class II oze 82, Subpa and main practices,	y having appliances or refrigeration equipment, air conditioning equipment, which use Class I or one-depleting substances as listed in 40 CFR Part rt A, Appendices A and B, shall service, repair, tain such equipment according to the work personnel certification requirements, and certified and recovery equipment specified in 40 CFR Part rt F.	335-3-1605(a)
	Class I or the repair,	shall knowingly vent or otherwise release any Class II substance into the environment during servicing, maintenance, or disposal of any device provided in 40 CFR Part 82, Subpart F.	
	recordkeep	nsible official shall comply with all reporting and bing requirements of 40 CFR 82.166. Reports ubmitted to the US EPA and the Department as	
26.	Chemical	Accidental Prevention Provisions	
	present in	cal listed in Table 1 of 40 CFR Part 68.130 is a process in quantities greater than the threshold sted in Table 1, then:	40 CFR Part 68
		owner or operator shall comply with the risions in 40 CFR Part 68.	
		owner or operator shall submit one of the wing:	
	(1)	A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR Part 68 § 68.10(a) or,	

Fede	rally Enforc	Regulations	
	(2)	A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.	
27.	Display of	Permit	
	at the site located an	t shall be kept under file or on display at all times where the facility for which the permit is issued is d will be made readily available for inspection by persons who may request to see it.	Rule 335-3-1401(1)(d
28.	Circumve	ntion_	
	any device reduction conceals o	shall cause or permit the installation or use of e or any means which, without resulting in in the total amount of air contaminant emitted, r dilutes any emission of air contaminant which erwise violate the Division 3 rules and regulations.	Rule 335-3-110
29.	Visible En	nissions	
	this permi discharge than 20% source dis emissions 40 CFR Pa	nerwise specified in the Unit Specific provisos of t, any source of particulate emissions shall not more than one 6-minute average opacity greater in any 60-minute period. At no time shall any charge a 6-minute average opacity of particulate greater than 40%. Opacity will be determined by art 60, Appendix A, Method 9, unless otherwise in the Unit Specific provisos of this permit.	Rule 335-3-401(1)
30.	Fuel-Burn	ing Equipment	
	prov may	ess otherwise specified in the Unit Specific risos of this permit, no fuel-burning equipment discharge particulate emissions in excess of the ssions specified in Rule 335-3-403.	Rule 335-3-403
	prov may	ess otherwise specified in the Unit Specific risos of this permit, no fuel-burning equipment discharge sulfur dioxide emissions in excess of emissions specified in Rule 335-3-501.	Rule 335-3-501

Fede	rally Enforceable Provisos	Regulations
31.	Process Industries - General	
	Unless otherwise specified in the Unit Specific provisos of this permit, no process may discharge particulate emissions in excess of the emissions specified in Rule 335-3-404.	Rule 335-3-404
32.	Averaging Time for Emission Limits	
	Unless otherwise specified in the permit, the averaging time for the emission limits listed in this permit shall be the nominal time required by the specific test method.	Rule 335-3-105
33.	Emissions Inventory Reporting Requirements	
	In order to meet the statewide emissions inventory reporting requirements under 40 CFR 51, Appendix A, the Permittee shall comply with the reporting requirements under ADEM Admin. Code R. 335-3-115.	Rule 335-3-115

Summary Page for Two (2) Combined Cycle Combustion Turbines and Two (2) Heat Recovery Steam Generators with Duct Burners and Selective Catalytic Reduction (SCR)

Permitted Operating Schedule: 8760 Hrs/yr

Emission limitations:

Emission Point #	Description	Pollutant	Emission limit (per CT)	Regulation
001, 002	CT1, CT2, each w/duct burner & SCR	NOx	0.009 lb/MMBtu & 24.6 lb/hr (3-hr rolling average)	ADEM Admin. Code r. 335-3-1404 BACT
			15 ppm at 15% O ₂ or 0.43 lb/MWh (30-day rolling average)	40 CFR 60 Subpart KKKK
			96 ppm at 15% O ₂ or 4.7 lb/MWh when operating at a <75% load. (30-day rolling average)	
		CO ¹	0.073 lb/MMBtu & 194 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		CO ²	0.022 lb/MMBtu & 59.6 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		VOCs	0.0068 lb/MMBtu & 18.1 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		PM	0.011 lb/MMBtu & 27.5 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		SO ₂	0.0056 lb/MMBtu & 15.2 lb/hr (3-hr rolling average)	ADEM Admin. Code r. 335-3-1404 BACT
			0.90 lb/MWh or 0.060 lb/MMBtu (3-hr rolling average)	40 CFR 60 Subpart KKKK
		Sulfuric Acid Mist	0.00086 lb/MMBtu & 2.3 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT

_

¹ These limits are for times when combustion turbine/duct burner is in operation.

² These limits are for times when only the combustion turbine is being operated.

Opacity	10% (6-min average)	ADEM Admin. Code r.
		335-3-1404
		BACT

Provisos for Two (2) Combined Cycle Combustion Turbines and Two (2) Heat Recovery Steam Generators with Duct Burners and Selective Catalytic Reduction (SCR)

Fed	erally Enforceable Provisos	Regulations
App	licability	
1.	These sources are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16, "Major Source Operating Permits."	Rule 335-3-16
2.	These sources are subject to the applicable requirements of ADEM Admin. Code R. 335-3-1404, "Air Permits Authorizing Construction in Clean Air Areas [Prevention of Significant Deterioration]."	Rule 335-3-1404
3.	The two (2) natural gas-fired combustion turbines are subject	Rule 335-3-1002(89)
	to the NSPS regulations for Stationary Gas Turbines, 40 CFR Part 60 Subpart KKKK.	40 CFR 60 Subpart KKKK
5.	The turbines and duct burners are subject to the applicable requirements of Subpart A, the General Provision of 40 CFR Part 60.	Rule 335-3-1002(1)
6.	These units are subject to the Acid Rain Rules contained in Rule 335-3-18 and 40 CFR Part 72, 75, and 76. The applicable Acid Rain Permit is contained in the Acid Rain portion of this Operating Permit.	Rule 335-3-18 and 40 CFR Parts 72, 75, and 76
7.	Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions are incorporated as enforceable conditions of this permit.	Rule 335-3-1605(a)2
8.	These sources are subject to the applicable provisions of the Cross-State Air Pollution Rule found in ADEM Admin. Code r. 335-3-506 through 335-3-536 and ADEM Admin. Code r. 335-3-807 through 335-3-870.	Rules 335-3-506 through 335-3-536 and Rules 335-3-807 through 335-3-870
<u>Emi</u>	ission Standards	

Fed	erally Enforceable Provisos	Regulations
1.	The nitrogen oxide emission rate from each combined turbine/duct burner stack shall not exceed 0.009 lb/MMBtu and 24.6 lb/hr. The nitrogen oxide emission rate shall be monitored using a rolling three-hour average computed by the continuous emission monitor system.	Rule 335-3-1404 BACT
2.	The nitrogen oxide emission rate from each combined turbine/duct burner stack shall not exceed 15 ppm (at 15% O ₂) or 0.43 lb/MWh of useful output. The nitrogen oxide emission rate shall not exceed 96 ppm (at 15% O ₂) or 4.7 lb/MWh of useful output when operating at a level less than 75% load. Both of these limits apply on a 30-day rolling average basis	Rule 335-3-1002(89) 40 CFR 60 Subpart KKKK
3.	The carbon monoxide emission rate from each combined turbine/duct burner stack shall not exceed 0.073 lb/MM Btu and 194 lb/hr. When firing the combustion turbine only, the carbon monoxide emission rate from each combined turbine/duct burner stack shall not exceed 0.022 lb/MM Btu and 59.6 lb/hr.	Rule 335-3-1404 BACT
4.	The volatile organic compound emission rate from each combined turbine/duct burner stack shall not exceed 0.0068 lb/MM Btu and 18.1 lb/hr.	Rule 335-3-1404 BACT
5.	The particulate matter emission rate from each combined turbine/duct burner stack shall not exceed 0.011 lb/MMBtu and 27.5 lb/hr.	Rule 335-3-1404 BACT
6.	Visible emission from the combined turbine and duct burner stack shall not exceed 10% opacity.	Rule 335-3-1404 BACT
7.	The sulfur dioxide emission rate from each combined turbine/duct burner stack shall not exceed 0.90 lb/MWh gross output or 0.060 lb/MMBtu heat input.	Rule 335-3-1002(89) 40 CFR 60 Subpart KKKK
8.	The sulfur dioxide emission rate from each combined turbine/duct burner stack shall not exceed 0.0056 lb/MWh and 15.2 lb/hr.	Rule 335-3-1404 BACT
9.	The sulfuric acid mist emission rate from each combined turbine/duct burner stack shall not exceed 0.00086 lb/MMBtu and 2.3 lb/hr.	Rule 335-3-1404 BACT

Fed	erall	y Enforceable Provisos	Regulations
10.	abo	eptions to the Rules and Regulations for provisos 1-9 we are granted for startup, shutdown, load change, and ntenance as defined below:	Rule 335-3-401(c)
	(a) Startup – The period from when the combustion turbine is started until it reaches the minimum load last approved by the Department. This period shall be readily identifiable on the load chart recording.		
	(b)	Shutdown – The period from when the combustion turbine is shutting down from the minimal load last approved by the Department to 0% load. This period shall be readily identifiable on the load chart recording.	
	(c)	Load Change – A rapid change in the electrical loading of a unit that is readily identifiable on the load chart recording.	
		The permittee shall take all reasonable actions to minimize the magnitude and duration of emissions during the periods listed above.	
11.	All emission limits (lb/MMBtu) are base on the Higher Heating Value (HHV).		Rule 335-3-1404 BACT
12.	The	turbines and duct burners shall fire only natural gas.	Rule 335-3-1404 BACT
13.	The combined hours of operation for power augmentation with duct firing, power augmentation alone, and duct firing alone shall not exceed 2,000 hours in any consecutive 12-month period.		Rule 335-3-1404 BACT
14.	Emissions exceeding any allowances that the source lawfully holds under Title IV of the Act or the regulations promulgated thereunder are prohibited.		Rule 335-3-1605(d)
15.	less star turk the com amb star Dep prev	se combustion turbines shall not be operated at a load than that designated as 45% except during periods of tup or shutdown or under the following conditions. Each sine may operate at a load below 45%, if compliance with emission standards in this permit has been verified by pliance tests and the owner or operator has completed bient air modeling confirming that all ambient air idards would be met at the minimum load tested. The artment must approve in writing any change to the riously approved lowest load of a turbine prior to operating uch load.	Rule 335-3-1404 BACT

Fee	derally Enforceable Provisos	Regulations
<u>Co</u> 1	mpliance and Performance Test Methods and Procedures	
1.	The continuous emissions monitor system (CEMS) required by Proviso 1 of the Emissions Monitoring section shall be used to determine compliance with the NOx limits in Proviso 1 of the Emission Standards section. Method 20 of Appendix A in 40 CFR Part 60 may also be used to determine the nitrogen oxides and oxygen concentrations.	Rule 335-3-1002(33); §64.2(b)(1)(iv); §60.335(c)(3) in 40 CFR Rule 335-3-1404 BACT
2.	Method 9 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the opacity standard.	Rule 335-3-105(1)
3.	Method 10 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the carbon monoxide emissions standards.	Rule 335-3-105(1)
4.	Method 5 or 17 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the particulate matter emissions standard.	Rule 335-3-105(1)
5.	Method 25, 25A, or 25B of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the volatile organic compounds emissions standards.	Rule 335-3-105(1)
6.	Method 6 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the sulfur dioxide emissions standards. Testing for sulfuric acid mist is not required if compliance with the sulfur dioxide emission limit in Emission Standards Proviso 8 is demonstrated.	Rule 335-3-105(1)
7.	Any performance tests required shall be conducted and data reduced in accordance with the test methods and procedures contained in each specific permit condition unless the Director (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) approves the use of an equivalent method, or (3) approves the	Rule 335-3-105(1)

Emission Monitoring

source is in compliance.

use of an alternative method, the results of which he has determined to be adequate for indicating whether a specific

Federally Enforceable Provisos

Regulations

1. The continuous emissions monitoring system (CEMS) to measure nitrogen oxide emissions shall continue to be operated at a location approved by the Director. The nitrogen oxide emission rate shall be monitored using a rolling three-hour average computed by the continuous emission monitor system. The CEMS shall meet the specifications and procedures of 40 CFR Part 75 and will be certified and maintained in accordance with 40 CFR Part 75.

Rule 335-3-14-.04 BACT 40 CFR 75

Recordkeeping and Reporting Requirements

1. An excess emissions report for the combined turbine/duct burner stack as defined by 40 CFR Part 60, Subpart A, §60.7(c) and (d), will be submitted to the ADEM within 30 days of the end of each calendar quarter in the following format:

Rule 335-3-16-.05(c) 40 CFR 64.9

NOx:

- (A) Source Operating Time (all times and periods in hours)
- (B) Time Monitoring System was Able to Record Source Performance*
- (C) Monitor Availability (%) = $B/A \times 100$
- (D) Total Emissions Periods where the Monitoring System determines emissions are above standards**
- (E) Overall Source Performance (%) = $[(B D) / B] \times 100$
- (F) Exempt Periods (as applicable)- F (x)
 - (1) F 1 = Startup/Shutdown
 - (2) F = 2 = 1 Load Change
- (G) Net Excess Emissions = D $\Sigma F(x)$
- (H) Net Source Performance (%):

=
$$[1 - (G/(B-\Sigma F(x)))] \times 100$$

= $[(B - \Sigma F(x) - G(x)) / (B - \Sigma F(x))] \times 100$

(I) Overall Exceedances (%) - Percent of time above the standard due to all reasons:

= 100-E

- (J) Net Exceedances (%) Percent of time above the standard due to non-exempt reasons:
 - = 100-H
- (K) Exempt Period Exceedances (%) Percent of time above the standard due to an exempted reason

$$SU/SD = (F1 / B) \times 100$$

Load Change = $(F2 / B) \times 100$

- * Information identifying each period during which the monitoring systems were inoperative (except for zero and span checks) and the nature of the system repairs or adjustments will be maintained and made available upon request.
- ** Report date, time, duration, magnitude, cause and corrective action taken for each occurrence.

NOTE: Data recorded during periods of system breakdowns, repairs, adjustments, and calibration checks shall not be included in any of the above data averages.

NOTE: Equations used to convert Monitoring System data as monitored to the required reporting standard will be provided with the first quarter report of each calendar year.

NOTE: The annual average emission rate of NO_x , in lb/MMBtu, and total heat input (MMBtu) loaded to each unit (turbine, duct burner) will be reported with the 4th Quarter report.

- 2. Records of monthly and rolling 12-month power augmentation with duct burning, power augmentation alone, and duct firing alone shall be maintained in a form suitable for inspection for a period of at least two years.
- 3. The facility shall comply with the recordkeeping and reporting requirements of CSAPR. Rules 335-3-5-.31, 335-3-5-.35, 335-3-8-.33, 335-3-8-.37, 335-3-8-.65, and 335-3-8-.69.

Rule 335-3-14-.04 BACT

Rules 335-3-5-.31, 335-3-5-.35, 335-3-8-.33, 335-3-8-.37, 335-3-8-.65, and 335-3-8-.69

Federally Enforceable Provisos	Regulations
Acid Rain Requirements	
1. These units are subject to the Acid Rain rules contained in 40 CFR Parts 72 and 75. Applicable Acid Rain permits are contained in the Acid Rain portion of this Operating Permit.	Rule 335-3-18 & 40 CFR Parts 72 and 75
CSAPR Requirements	
1. These units are subject to the applicable provisions of Cross-State Air Pollution Rule(CSAPR) to include all applicable provisions of the SO ₂ Group 2 Trading Program requirements.	Rules 335-3-506 through 335-3-536
2. These units are subject to the applicable provisions of Cross-State Air Pollution Rule(CSAPR) to include all applicable provisions of the NOx Annual Trading Program requirements.	Rules 335-3-806 through 335-3-870

Summary Page for 11.64 MMBtu/hr Indirect-fired Fuel Heater

Permitted Operating Schedule: $8760~\mathrm{Hrs/yr}$

Emission limitations:

Emission Point #	Description	Pollutant	Emission limit (per CT)	Regulation
003	11.64 MMBtu/hr Fuel Heater	NOx	0.13 lb/MMBtu & 1.6 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		СО	0.081 lb/MMBtu & 0.94 lb/hr	ADEM Admin. Code r. 335-3-1404 BACT
		PM	Unit shall only fire pipeline quality natural gas.	ADEM Admin. Code r. 335-3-1404 BACT
		SO ₂	Unit shall only fire pipeline quality natural gas.	ADEM Admin. Code r. 335-3-1404 BACT

Provisos for 11.64 MMBtu/hr Indirect-fired Fuel Heater

Fed	lerally Enforceable Provisos	Regulations
App	olicability	
1.	This source is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16, "Major Source Operating Permits."	Rule 335-3-16
2.	This source are subject to the applicable requirements of ADEM Admin. Code R. 335-3-1404, "Air Permits Authorizing Construction in Clean Air Areas [Prevention of Significant Deterioration]."	Rule 335-3-1404
3.	The indirect-fired fuel heater is subject to the NSPS	Rule 335-3-1002(2)(c)
	regulations for Small Industrial-Commercial-Institutional Steam Generating Units, 40 CFR Part 60 Subpart D _c .	40 CFR 60 Subpart D _c
<u>Em</u>	ission Standards	
1.	The nitrogen oxide emission rate from the fuel heater stack	Rule 335-3-1404
	shall not exceed 0.13 lb/MMBtu and 1.6 lb/hr.	BACT
2.	The carbon monoxide emission rate from the fuel heater shall	Rule 335-3-1404
	not exceed 0.081 lb/MM Btu and 0.94 lb/hr.	BACT
3.	The fuel heater shall only fire pipeline quality natural gas.	Rule 335-3-1404
		BACT
Con	npliance and Performance Test Methods and Procedures	
1.	Method 20 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the nitrogen oxides emissions standards.	Rule 335-3-105(1)
2.	Method 9 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the opacity standard.	Rule 335-3-105(1)
3.	Method 10 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the carbon monoxide emissions standards.	Rule 335-3-105(1)
4.	Method 5 or 17 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the particulate matter emissions standard.	Rule 335-3-105(1)

Fed	lerally Enforceable Provisos	Regulations
5.	Method 25, 25A, or 25B of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the volatile organic compounds emissions standards.	Rule 335-3-105(1)
6.	Method 6 of Appendix A in 40 CFR Part 60 shall be used in the determination of compliance with the sulfur dioxide emissions standards.	Rule 335-3-105(1)
7.	Any performance tests required shall be conducted and data reduced in accordance with the test methods and procedures contained in each specific permit condition unless the Director (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) approves the use of an equivalent method, or (3) approves the use of an alternative method, the results of which he has determined to be adequate for indicating whether a specific source is in compliance.	Rule 335-3-105(1)
<u>Em</u>	ission Monitoring	
1.	There are no source specific emissions monitoring provisions for this unit.	N/A
Rec	ordkeeping and Reporting Requirements	
1.	There are no source specific recordkeeping and reporting requirement provisions for this unit.	N/A

Summary Page for MACT Subpart ZZZZ – Existing Emergency Firewater Pump

Permitted Operating

Schedule*: 24 Hrs/day x 7 Days/week x 52 Weeks/yr = 8760 Hrs/yr

Emission limitations:

Emission Point #	Description	Pollutant	Emission limit	Regulation
004	805 HP Diesel Fired Emergency Firewater Pump	PM	N/A	N/A
004	805 HP Diesel Fired Emergency Firewater Pump	SO ₂	N/A	N/A
004	805 HP Diesel Fired Emergency Firewater Pump	NOx	N/A	N/A
004	805 HP Diesel Fired Emergency Firewater Pump	СО	N/A	N/A
004	805 HP Diesel Fired Emergency Firewater Pump	VOC	N/A	N/A
004	805 HP Diesel Fired Emergency Firewater Pump	Opacity	See General Provisos	Rule 335-3-401(1)

^{*}Operating hours limited to 100 hrs/yr in non-emergency situations

Provisos for MACT Subpart ZZZZ – Existing Emergency RICE Engines

Fede	rally Enforceable Provisos	Regulations
Appl	icability	
1.	This source is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits".	Rule 335-3-1603
2.	This source is subject to the applicable requirements of 40 CFR Part 63 Subpart ZZZZ, "National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE)".	40 CFR Part 63 Subpart ZZZZ
3.	This source is subject to the applicable requirements of Subpart A of 40 CFR Part 63, "General Provisions" as listed in Table 8 of Subpart ZZZZ.	40 CFR Part 63 Subpart ZZZZ
<u>Emis</u>	ssion Standards	
1.	This source is subject to the applicable requirements listed in Table 2d of 40 CFR 63 Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	40 CFR §63.6603
2.	The Permittee must operate and maintain this unit according to the manufacturer's emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.	40 CFR §63.6625(e)(3)
3.	The firewater pump shall be equipped with a non-resettable hour meter.	40 CFR §63.6625(f)
4.	This unit may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of these units are limited to 100 hours per year. There is no time limit on the use of these units in emergency situations. The owner or operator may petition the Administrator for approval of additional hours to be	40 CFR §63.6640(f)

Federally Enforceable Provisos

Regulations

used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. This unit may operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for nonemergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply non-emergency power as part of a financial arrangement with another entity. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as permitted in 40 CFR 63 Subpart ZZZZ, is prohibited.

Compliance and Performance Test Methods and Procedures

1. Method 9 of 40 CFR (Latest Edition) Part 60, Appendix A shall be used in the determination of the opacity.

Rule 335-3-1-.05

Emission Monitoring


- 1. The Permittee shall perform the following activities:
 - (a) Change oil and filter every 500 hours of operation or annually, whichever comes first;
 - (b) Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;
 - (c) Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

Or utilize an oil analysis program as described in §63.6625(i).

40 CFR Part 63 Subpart ZZZZ Table 2d

§63.6625(i)

Fede	rally Enforceable Provisos	Regulations
2.	If an oil analysis program is utilized for a stationary compression ignition engine, the Permittee must perform the oil analysis at the same frequency specified above for changing the oil. The Permittee must at a minimum analyze the following parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new, viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new, or percent water content (by volume) is greater than 0.5. If any of the limits are exceed, the Permittee must change the oil within 2 business days of receiving the results of the analysis or before commencing operation, whichever is later.	40 CFR Subpart ZZZZ §63.6625(i)
Recor	rdkeeping and Reporting Requirements	
1.	The Permittee must keep records of the parameters that are analyzed as part of the oil analysis program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.	40 CFR Subpart ZZZZ §63.6625(i)
2.	The Permittee must keep records of the maintenance conducted on this unit in order to demonstrate that you operated and maintained this unit and after-treatment control device (if any) according to your own maintenance plan or according to manufacturer's written instructions.	40 CFR §63.6655(e)
3.	The Permittee must keep records of the hours of operation of each engine that is recorded through the non-resettable hour meter. The facility must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation.	40 CFR §63.6655(f)



Phase II Acid Rain Permit

Issued by: Alabama Department of Environmental Management

Issued to: Hillabee Power Plant Operated by: CER Generation, LLC

ORIS Code: 55411 Effective: DRAFT

Acid Rain Permit Contents

- 1) Statement of Basis
- 2) SO₂ allowances allocated under this permit and NO_x requirements for each affected unit.
- 3) Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process and any additional requirements or conditions.
- 4) The Phase II Permit Application submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the Phase II Permit Application.
- 5) Summary of Previous Actions and Current Action.

1) Statement of Basis:

Statutory and Regulatory Authorities: In accordance with the Code of Alabama 1975, §§ 22-22A-4, 22-22A-6, 22-22A-8, 22-28-14, and Titles IV and V of the Clean Air Act, the Alabama Department of Environmental Management issues this permit pursuant to ADEM Admin. Codes 335-3-16 and 335-3-18.

2) SO₂ Allowance Allocations and NO_x Requirements for each affected unit:

h-		2016	2017	2018	2019	2020
CT-1	SO ₂ allowances, under 40 CFR part 73 [tons]	${\sf NA}^1$	${\sf NA}^1$	NA^1	NA¹	NA¹
	NO _x limit [lb/MMBtu]	¤2	¤2	¤2	¤2	¤2

t-		2016	2017	2018	2019	2020
CT-2	SO ₂ allowances, under 40 CFR part 73 [tons]	NA^1	${\sf NA}^1$	NA^1	NA^1	NA¹
	NO _x limit [lb/MMBtu]	¤2	¤2	¤2	¤2	¤2

1 Currently there are no SO₂ allowances allocated to these units by the U.S. EPA. The number of allowances allocated to Phase II affected units by U.S. EPA may change under 40 CFR Part 73. In addition, the number of allowances actually held by an affected source in a unit account may differ from the number allocated by

- U.S. EPA. Neither of the aforementioned conditions necessitate a revision to SO₂ allowance allocations identified in this permit [See 40 CFR 72.84].
- 2 40 CFR Part 76 does not establish a NOx emission rate for Combined Cycle Combustion Turbine Units CT-1, CT-2.
- **Comments, Notes, and Justifications:** This facility consists of two combined cycle 229 MW (nominal) Natural Gas Fired Combustion Turbines each with a Natural Gas Fired 196 MMBtu/hr (HHV) Duct Burner and Heat Recovery Steam Generator. The Heat Recovery Steam Generators supply steam to a steam turbine.

It should be noted that the compliance certification report shall cover each calendar year in which year the unit is subject to an Acid Rain limitation.

4) Phase II Permit Application: Attached.

5) Summary of Previous Actions and Current Action:

	Action	Date
1.	Draft permit prepared and submitted for public review and comment.	March 22, 2011
2.	Permit finalized and issued.	May 9, 2011
3.	Draft permit prepared and submitted for public review and comment.	DATE
4.	Permit finalized and issued.	DATE
	Ronald W. Gore, Chief Air Division	Date



Identify the facility name,

State, and plant (ORIS)

STEP 1

code.

STEP 2

Enter the unit ID#

for every affected

unit at the affected source in column "a."

United States Environmental Protection Agency Acid Rain Program

OMB No. 2060-0258 Approval expires 11/30/2012

Acid Rain Permit Application

For more information, see instructions and 40 CFR 72.30 and 72.31. This submission is: New Revised X for ARP permit renewal Facility (Source) Name State Plant Code Hillabee Energy Center AL 55411 b a Unit ID# Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1) CT1 Yes CT2 Yes

Facility (Source) Name (from STEP 1)

Permit Requirements

STEP 3

Read the standard requirements.

(1) The designated representative of each affected source and each affected unit at the source shall:

(i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and

(ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;

(2) The owners and operators of each affected source and each affected unit at the source shall:

(i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and

(ii) Have an Acid Rain Permit.

Monitoring Requirements

(1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.

(2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.

(3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and

(ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.

- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).

Sulfur Dioxide Requirements, Cont'd.

STEP 3, Cont'd.

(4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.

(5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to

the calendar year for which the allowance was allocated.

(6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.

(7) An allowance allocated by the Administrator under the Acid Rain

Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

(1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.

(2) The owners and operators of an affected source that has excess

emissions in any calendar year shall:

(i) Pay without demand the penalty required, and pay upon demand the

interest on that penalty, as required by 40 CFR part 77; and

(ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

(1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:

(i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the

Facility (Source) Name (from STEP 1)

submission of a new certificate of representation changing the designated representative;

STEP 3, Cont'd. Recordkeeping and Reporting Requirements, Cont'd.

(ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain

Program: and.

(iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain

Program.

(2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C.

1001

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each affected source and each affected unit shall meet the

requirements of the Acid Rain Program.

(5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.

(6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.

(7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

Facility (Source) Name (from STEP 1)

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating

STEP 3, Cont'd.

Effect on Other Authorities, Cont'd.

to applicable National Ambient Air Quality Standards or State Implementation Plans:

(2) Limiting the number of allowances a source can hold; *provided*, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements

under such State law:

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4
Read the certification statement, sign, and date.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Date 10/29:115